

# ASTA

## CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: LSWGWO0077053/01

Certificate No. 18087

**APPARATUS:** 6A to 40A, 30mA Residual current operated circuit-breakers with integral over-current protection for household and similar uses (RCBOs), Double Pole (Phase & Neutral) with one over current protection pole and uninterrupted neutral pole, 240V(U<sub>n</sub>), 50/60Hz. 55°C Mounting Connection: plug in and DIN Rail wire in /wire out (screw type terminals)

**DESIGNATION:** FTCOP.1006A TO 1040A & FTCOD.1006A TO 1040A

**MANUFACTURER:** Farraj Trading & Manufacturing Co.,  
P.O. Box 61122, Jebel Ali, Dubai, United Arab Emirates

**TESTED BY:** Electrical Research & Development Association  
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, Gujarat, INDIA

**DATES OF TESTS:** 9<sup>th</sup> November 2009 to 6<sup>th</sup> April 2011

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

IEC 61009-1: 2006  
Test Sequences: A, B, C, D<sub>0</sub>, D<sub>1</sub>, E<sub>0</sub>, E<sub>1</sub>, F<sub>0</sub>, F<sub>1</sub> & G.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance is considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as stated below.

**For ratings assigned by the manufacturer and proved by the tests, see page 1.**

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 58 pages, 2 diagrams, 116 oscillograms, 42 photographs, 47 drawings and no other sheets as detailed on page 3, 4 & 5

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from INTERTEK Testing & Certification Ltd, Hilton House, Corporation Street, Rugby. CV21 2DN, England.



010

*Rajani Menon*  
..... Rajani Menon  
ASTA Observer  
*R. Raymond*  
..... Certification  
Manager  
*15<sup>th</sup> April 2011*  
..... Date

### **ASTA Certificates, ASTA Licences and ASTA Test Reports**

ASTA Certificates, ASTA Licences and ASTA Test Reports are issued by Intertek for the exclusive use of the party applying for the Certificate, Licence or Test Report and any related testing. Intertek assumes no liability to any parties other than those with which it has an agreement and then only in accordance with the agreed Terms and Conditions.

The Applicant is authorised to copy or distribute ASTA Certificates, ASTA Licences and ASTA Test Reports provided the entire contents are included, or Certificate Front Sheets accompanied by any associated pages on which are stated the assigned rated characteristics and no part is obscured or illegible, or Licence front sheets. Permission must be obtained from Intertek before any other kind of reproduction is made.

The holder of an ASTA Certificate may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in an ASTA Certificate is ASTA Certified.

The holder of an ASTA Licence may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in an ASTA Licence is ASTA Approved.

To minimise the possibility of any misunderstanding such claims must clearly identify the product(s) certified or approved, the ratings verified by ASTA and the Standard against which certification/approval has been made.

Any other use of the Intertek or ASTA names must first be approved in writing by Intertek. Test results and ratings proven by testing included in ASTA Certificates and ASTA Test Reports relate specifically to the sample(s) tested.

### **Types of ASTA Certificates**

Certificates are issued when samples of a particular product design have been tested satisfactorily against the requirements of a National, European, International or ASTA Standard. Several forms of Certificate are available, including:

#### **Certificate of Complete Compliance**

Verifies compliance with all the requirements of a Standard

#### **Certificate of Type/Verification Tests**

Verifies complete series of type/verification tests prescribed in a Standard has been made successfully.

#### **Certificate of Selected Type/Verification Tests**

Verifies specified type/verification tests have been made successfully

#### **Supplementary Certificate**

Extends the scope of an existing Certificate to cover changes in rating or in design

### **ASTA Test Report**

An ASTA Test Report is issued when tests otherwise satisfactory cannot be included in a Certificate for one or more reasons, e.g. verification of non-standard ratings

### **ASTA Licences and ASTA Diamond Mark**

The use of the ASTA Diamond Mark on products is authorised by an ASTA Licence. Products covered by an ASTA Licence can be referred to as ASTA Approved. Requirements for ASTA Licences include testing for full compliance with relevant standards and satisfactory, on-going assessment of production. Validity and use of ASTA Licences are subject to compliance with Intertek ASTA & BEAB Marks Certification Regulations.

### **Authenticity**

Authenticity of any ASTA document can be confirmed by contacting Intertek's Rugby office, telephone +44 1788 578435 or [asta@intertek.com](mailto:asta@intertek.com)

### Ratings Assigned by the Manufacturer and Proved by Tests

Rated current (Range) ( $I_n$ ):	6A - 40A
Rated residual operating current (Range) ( $I_{\Delta n}$ ):	30mA
Rated residual non-operating current (Range) ( $I_{\Delta no}$ ):	15mA
Rated voltage ( $U_e$ ):	240V
Rated insulation voltage ( $U_i$ ):	500V
Rated impulse withstand voltage ( $U_{imp}$ ):	4kV
Number of Poles and current paths:	Double pole (Phase & Neutral) RCBO with one over current protection pole and uninterrupted Neutral pole
Rated frequency:	50/60Hz
Rated residual making and breaking capacity ( $I_{\Delta m}$ ):	500A
Rated short-circuit capacity ( $I_{cn}$ ):	10kA
RCBO type (General/S):	General type
Operating characteristics in case of residual current with D.C. components:	Type AC
Degree of protection:	IP20
Pollution degree/ Material Group:	2/II
RCBO functionally dependent/independent on line voltage:	Functionally dependent on line voltage
Type of installation:	Fixed installation and fixed wiring
Adjustable/ fixed residual operating current:	Fixed residual operating current
Enclosed type/ non enclosed type:	Enclosed type
Method of mounting:	Surface type
Method of connection:	Plug-in, Din Rail type
Instantaneous tripping current type:	C - type
Suitable for IT system:	No

**Ratings Assigned by the Manufacturer and Proved by Tests (continued)**

- |  |          |
|--|----------|
| 1. <b>Test Sequence A:</b><br>(Clauses 6, 8.1.1, 8.1.2, 9.3, 8.1.3, 8.1.6, 9.11, 9.4, 9.5, 9.6, 9.14, 8.1.3, 9.15)           | Verified |
| 2. <b>Test Sequence B:</b><br>(Clauses 9.7, 9.8, 9.20, 9.22.2, 9.23)   | Verified |
| 3. <b>Test Sequence C (C<sub>1</sub> &amp; C<sub>2</sub>):</b><br>(Clauses 9.10, 9.12.11.2.1, 9.12.12, 9.12.11.2.2, 9.12.12) | Verified |
| 4. <b>Test Sequence D<sub>0</sub>:</b><br>(Clauses 9.9.1)  | Verified |
| 5. <b>Test Sequence D<sub>1</sub>:</b><br>(Clauses 9.17, 9.19, 9.21, 9.12.13, 9.16)  | Verified |
| 6. <b>Test Sequence E<sub>0</sub>:</b><br>(Clauses 9.9.2, 9.18)  | Verified |
| 7. <b>Test Sequence E<sub>1</sub>:</b><br>(Clauses 9.13, 9.12.3, 9.12.12)  | Verified |
| 8. <b>Test Sequence F<sub>0</sub>:</b><br>(Clauses 9.11.2.4 b), 9.12.12,)  | Verified |
| 9. <b>Test Sequence F<sub>1</sub>:</b><br>(Clauses 9.11.2.4 c, 9.12.12.2)  | Verified |
| 10. <b>Test Sequence G :</b><br>(Clauses 9.22.1)   | Verified |