

ASTA

CERTIFICATE OF TYPE TESTS

Laboratory Ref. No: LSWGWO0097974/01

Certificate No. **18605**.....

APPARATUS: Unenclosed, changeable trip unit/adjustable, 3-Pole, 50/60Hz, Moulded Case Circuit-breaker, fitted with adjustable Over Current Releases. $I_n = 250A$ (maximum current setting), $U_e = 415/400V$, $U_i = 750V$, $U_{imp} = 8kV$. Utilisation Category A, Terminals marked: Line and Load, Reference Ambient Temperature 55°C

DESIGNATION: FTCJ3250

MANUFACTURER: Farraj Trading & Manufacturing Co,
P.O. Box 61122, Jebel Ali Free Zone, Dubai, United Arab Emirates

TESTED BY: Electrical Research & Development Association
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, Gujarat, INDIA

DATES OF TESTS: 3rd December 2011 to 16th February 2012

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

**IEC 60947 -2: 2009-05 Edition 4.1 with Amendment 1: 2009 - Clause 8.3.3, 8.3.4 & 8.3.5
Test sequence I, II & III**

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance is considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by the tests see page 1.

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 26 pages, 1 diagram, 27 oscillograms, 23 photographs, 36 drawings and no other sheets as detailed on pages 2 & 3

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission Intertek Testing and Certification Ltd, Hilton House, Corporation Street, Rugby. CV21 2DN, England.



010

Rajani Menon
.....
Rajani Menon
ASTA Observer

P. J. Das
.....
Certification
Manager

11TH APRIL 2012
.....
Date

RECORD OF PROVING TESTS

Laboratory Ref. No: LSWGWO97974/01

ASTA

Page 1 of 26

Ratings Assigned by the Manufacturer and Proved by Tests

Test Sequence I: General performance characteristics (Clause 8.3.3):

Tripping limits and characteristics (Clause 8.3.3.1):	Verified
Dielectric properties (Clause 8.3.3.2):	Verified
Rated operational voltage (U_o):	415 V
Rated insulation voltage (U_i):	750 V
Rated Impulse withstand voltage (U_{imp}):	8 kV
Mechanical operation and operational performance capability (Clause 8.3.3.3):	Verified
Overload performance (Clause 8.3.3.4):	Not applicable
Verification of dielectric withstand (Clause 8.3.3.5):	Verified
Verification of temperature-rise (Clause 8.3.3.6):	Verified
Rated current (I_n):	250 A
Verification of overload releases (Clause 8.3.3.7):	Verified
Verification of under voltage and shunt releases (If applicable) (Clause 8.3.3.8):	Not applicable
Verification of main contact position (Clause 8.3.3.9): (for circuit breaker suitable for isolation)	Verified

Test Sequence II (Clause 8.3.4) & III (Clause 8.3.5):

Verification of overload releases (Clause 8.3.5.1):	Verified
Rated short-circuit breaking capacity (Clause 8.3.4.1 & 8.3.5.2)	Verified
Rated service short-circuit breaking capacity (Ics):	65kA at 415V, pf=0.2
Rated ultimate short-circuit breaking capacity (Icu):	65kA at 415V, pf=0.2
Verification of operational capability (Clause 8.3.4.2):	Verified
Verification of dielectric withstand (Clause 8.3.4.3):	Verified
Verification of temperature-rise (Clause 8.3.4.4):	Verified
Verification of overload releases (Clause 8.3.4.5):	Verified
Verification of overload releases (Clause 8.3.5.4):	Verified

Date of tests: 3rd December 2011 to 16th February 2012



Rajani Menon, ASTA Observer